









Atemschutzmaske

EN 149:2001+A1:2009 FFP2 NR

Adresse: No. 3548, Kanglong Village, Gaokou Town, Cangshan County, Henan City,
Zhejiang Province, CHINA

Hersteller: Cangshan County Jiawei Bag Making Factory

Tel: 0577-64486858

Europäischer Importeur / European importer:

Paul Schrick-Kistele Doc.
Dufourstrasse 28
54187 Leipzig
Germany

● Gebrauchsanweisung

- 1 Halten Sie die Maske über Nase und Mund.
- 2 Legen Sie die Ohrschlaufen hinter die Ohren.
- 3 Drücken Sie den Nasendip an der Oberseite der Maske an die Wangen, um eine gute Abdichtung zu erzielen.
- 4 Prüfen Sie den korrekten Sitz, indem Sie beide Hände über die Maske halten und atmen Sie kräftig. Falls Luft an den Seiten oder der Oberseite austritt, passen Sie Ohrschlaufen oder Nasendip an, bis die Abdichtung ordnungsgemäß ist.
- 5 Nur eine ordnungsgemäße Abdichtung kann die vollständige Schutzwirkung der Maske gewährleisten.



	Datum abgelaufen / Date expired
	Herstellungsdatum / Date of manufacture
	Chargennummer / Batch code
	Nicht wiederverwenden! Do not reuse
	Sehe die Angaben des Herstellers / See the information supplied by the manufacturer
	Maximale relative Luftfeuchtigkeit / Maximum Relative Humidity
	Temperaturbereich / Temperature range
	Hersteller / Manufacturer

Certification of Approval
product Name: CNJW-2020 FFP2 NR (Non-Medical Face Mask)
Model & Specification: CNJW-2020 FFP2 NR
Material: Composite Double-Strap Nonwoven Fabric, 25g/m² (inner layer), 25g/m² (outer layer)
Qty. per lot: 1000
product Quantity / Piece Pack: 1000
Execution Standard: EN 149:2001+A1:2009
Batch Code: 20201228
Date of Manufacture: 2020.12.28
Validity: 30 Months
Inspection: 01
For more information, please refer to the instruction on the package!
Address: No. 3548, Kanglong Village, Gaokou Town, Cangshan County, Henan City,
Zhejiang Province, CHINA
Hersteller: Cangshan County Jiawei Bag Making Factory
Tel: 0577-64486858
Made in China

CE 0598

1pc

CE 0598



Certificate FI20/967675

Cangnan County Jiawei Bag Making Factory

No.39-40, Xiangdong Village, Qian Ku Town, Cangnan County,
Wenzhou City, Zhejiang Province, China


It is certified that the manufacturer's technical file and the PPE product detailed on
page 2 have been assessed and found to be in accordance with

Regulation (EU) 2016/425

Module B, EU type-examination

This certificate is valid from 15 December 2020 until 15 December 2025
1. Certified since 15 December 2020

Authorised by



FINAS
Finnish Accreditation Service
S003 (EN ISO/IEC 17065)

SGS FIMKO OY, Notified Body 0598

Takomitie 8, FI-00380, Helsinki, Finland
t +358 9 696 361 f +358 9 692 5474 www.sgs.com

Page 1 of 2



This document is issued by the Company subject to its General Conditions of
Certification Services accessible at www.sgs.com/terms_and_conditions.htm.
Attention is drawn to the limitations of liability, indemnification and jurisdictional
issues established therein. The authenticity of this document may be verified at
<http://www.sgs.com/en/certified-clients-and-products/certified-client-directory>.
Any unauthorized alteration, forgery or falsification of the content or appearance
of this document is unlawful and offenders may be prosecuted to the fullest
extent of the law.

Certificate FI20/967675, continued

Cangnan County Jiawei Bag Making Factory

Regulation (EU) 2016/425

Module B, EU type-examination

Issue 1

PPE Product

JW (logo) CNJW-2020 particle filtering half mask, consisting of a white five layer (polypropylene/ polypropylene/ polypropylene / polypropylene / polypropylene) disposable face mask, with nose clip and nylon/ spandex ear loop.

It is certified that the manufacturer's technical file and the above mentioned PPE have been assessed and found to meet the applicable Essential Health and Safety Requirements in Annex II of Regulation (EU) 2016/425 Personal Protective Equipment

The following have been applied:

EN 149:2001+A1:2009 (Respiratory protective devices - filtering half masks to protect against particles) device classification: FFP2 NR.

This certificate is issued on the strict condition that appropriate checks on manufactured PPE, as detailed in Article 19 (c) of the Regulation are implemented and maintained while the model is in production

Certification is based on technical file reference:

Face mask / CNJW-2020, version1, dated: 2020-10-20.

SGS Reference Number UK/CRS 242444.

This certificate remains the property of SGS Fimko Oy to whom it must be returned on request

Cangnan County Jiawei Bag Making Factory

No.39-40, Xiangdong Village, Qian Ku Town, Cangnan County,
Wenzhou City, Zhejiang Province, China

It is certified that the manufacturer's technical file and the PPE product detailed on
page 2 have been assessed and found to be in accordance with

Regulation (EU) 2016/425

Module B, EU type-examination

This certificate is valid from 15 December 2020 until 15 December 2025
1. Certified since 15 December 2020

Authorised by



SGS FIMKO OY, Notified Body 0598

Takomotie 8, FI-00380, Helsinki, Finland
t +358 9 696 361 f +358 9 692 5474 www.sgs.com



Cangnan County Jiawei Bag Making Factory

Regulation (EU) 2016/425

Module B, EU type-examination

Issue 1

PPE Product

JW (logo) CNJW-2020 particle filtering half mask, consisting of a white five layer (polypropylene/ polypropylene/ polypropylene / polypropylene / polypropylene) disposable face mask, with nose clip and nylon/ spandex ear loop.

It is certified that the manufacturer's technical file and the above mentioned PPE have been assessed and found to meet the applicable Essential Health and Safety Requirements in Annex II of Regulation (EU) 2016/425 Personal Protective Equipment

The following have been applied:

EN 149:2001+A1:2009 (Respiratory protective devices - filtering half masks to protect against particles) device classification: FFP2 NR.

This certificate is issued on the strict condition that appropriate checks on manufactured PPE, as detailed in Article 19 (c) of the Regulation are implemented and maintained while the model is in production

Certification is based on technical file reference:

Face mask / CNJW-2020, version1, dated: 2020-10-20.

SGS Reference Number UK/CRS 242444.

This certificate remains the property of SGS Fimko Oy to whom it must be returned on request



Certificate CN20/42715

The management system of

Cangnan County Jiawei Bag Making Factory

No.39-40, Xiangdong Village, Qian Ku Town, Cangnan County,
Wenzhou City, Zhejiang Province, China

has been assessed and certified as meeting the requirements of

Regulation (EU) 2016/425 Module C2

For the following activities

Manufacture of JW (logo) CNJW-2020 particle filtering half mask.
(Note: All products marked CE0598 must have a valid EU type-examination certificate issued under Module B or a valid EC type-examination certificate issued under Article 10 of Directive 89/686/EEC.)

This certificate is valid from 22 December 2020
and remains valid subject to satisfactory surveillance audits.
Issue 1. Certified since 22 December 2020

Authorised by



SGS FIMKO OY, Notified Body 0598

Takomotie 8, FI-00380 Helsinki, Finland
t +358 9 696 361 f +358 9 692 5474 www.sgs.com



Page 1 of 1

CANGNAN COUNTY JIAWEI BAG MAKING FACTORY
NO.39-40, XIANGDONG VILLAGE, QIAN KU TOWN, CANGNAN COUNTY, WENZHOU CITY, ZHEJIANG PROVINCE

THIS REPORT CANCELS AND SUPERSEDES THE TEST REPORT NO.SL52035285157101TX DATE: 2020-08-26 ISSUED BY SGS (Shanghai) UPDATED SAMPLE INFORMATION.

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : (A) Disposable preventive mask

SGS Internal Ref.No. : CP20-040466

Sample Color : (A) WHITE

Item No. : Melt-blown fabric

Model No. : CNJW-2020

Manufacturer : CANGNAN COUNTY JIAWEI BAG MAKING FACTORY

Supplier : CANGNAN COUNTY JIAWEI BAG MAKING FACTORY

Other Info. : Batch No.: 20200728, Specifications: CNJW-2020

Material quality : double S25g non-woven fabric, 25g melt-blown fabric, 40g hot air cotton

Test Performed : Selected test(s) as requested by applicant

Sample Receiving Date : Aug 06, 2020

Testing Period : Aug 06, 2020 - Aug 26, 2020

Test Result(s) : Unless otherwise stated the results shown in this test report refer only to the sample(s) tested, for further details, please refer to the following page(s).

Sample No.	Recommendation Level
(A)	FFP2 NR

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd Testing Center

Sara Guo

Sara Guo (Account Executive)



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

3rd Building, No. 889, Yishan Road, Xuhui District Shanghai, China 200233
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233

t (86-21) 61402666 f (86-21) 64958763
t (86-21) 61402666 f (86-21) 64958763

www.sgs.com
sgs.china@sgs.com

Test Result

Personal Protective Equipment - Respiratory Protective Devices- Filtering Half Masks to Protect against Particles- Requirements, Testing, Marking

EN 149:2001+A1:2009

Clause 7.4 Packaging

(EN 149:2001+A1:2009 Clause 8.2)

Test Requirement	Results	Comment
Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.	Comply	Pass

Clause 7.5 Material

(EN 149:2001+A1:2009, Clause 8.2 & 8.3.1 & 8.3.2)

Test Requirement	Results	Comment
Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used.	Comply	Pass
After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps.	Comply	
When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse.	Comply	
Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Comply	

Clause 7.6 Cleaning and Disinfecting

(EN 149:2001+A1:2009, Clause 8.4 & 8.5 & 8.11)

Test Requirement	Results	Comment
If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer. With reference to 7.9.2, after cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.	Not applicable (Not designed to be re-usable)	N.A.

Clause 7.7 Practical Performance

(EN 149:2001+A1:2009, Clause 8.4)

Test Requirement	Results	Comment
The particle filtering half mask shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the equipment for imperfections that cannot be determined by the tests described elsewhere in this standard.	No imperfections	Pass



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

3rd Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233

t (86-21) 61402666

f (86-21) 64958763

www.sgs.com

中国·上海·徐汇区宜山路889号3号楼 邮编: 200233

t (86-21) 61402666

f (86-21) 64958763

sgs.china@sgs.com

Clause 7.8 Finish of Parts

(EN 149:2001+A1:2009, Clause 8.2)

Test Requirement	Results	Comment
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	No sharp edges or burrs	Pass

Clause 7.9.1 Total Inward Leakage

(EN 149:2001+A1:2009, Clause 8.5)

Test Requirement	Results	Comment
<p>The total inward leakage consists of three components: face seal leakage, exhalation value leakage(if exhalation value fitted) and filter penetration. For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual exercise results (i.e. 10 subjects x 5 exercises) for total inward leakage shall be not greater than: 25% for FFP1, 11% for FFP2, 5% for FFP3</p> <p>and, in addition, at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall be not greater than: 22% for FFP1, 8% for FFP2, 2% for FFP3</p>	Detail refer to Appendix 1	Meet FFP1, Meet FFP2

Appendix 1: Summarization of Test Data

Inward Leakage Test Data

Subject	Sample No.	Condition	Walk(%)	Head Side/side(%)	Head up/down(%)	Talk(%)	Walk(%)	Mean(%)
Zhou	1	A.R.	6.65	6.19	6.60	5.87	5.15	6.09
Luo	2	A.R.	7.48	5.51	7.86	7.31	7.35	7.18
Lu	3	A.R.	5.12	4.78	7.51	6.19	7.09	6.14
Wang	4	A.R.	5.35	4.47	6.78	4.35	5.02	5.19
Bao	5	A.R.	7.91	7.42	7.40	6.96	6.36	7.21
Ding	6	T.C.	5.00	5.89	5.24	5.55	5.66	5.47
Li	7	T.C.	6.19	8.23	7.14	8.33	7.79	7.54
Chen	8	T.C.	7.40	4.43	6.20	4.95	5.27	5.65
Song	9	T.C.	7.16	5.84	6.89	7.13	6.25	6.65
Ye	10	T.C.	7.42	8.18	6.61	8.87	6.77	7.57

Facial Dimension(mm)

Subject	Face length	Face Width	Face Depth	Mouth Width
Chen	125	150	120	58
Lu	115	132	107	48
Zhou	115	135	106	52
Li	125	130	107	46
Luo	125	136	100	43
Zheng	128	140	112	55
Wang	120	147	103	48
Song	120	140	100	50
Bao	130	134	104	50

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

3rd Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233

t (86-21) 61402666 f (86-21) 64958763
t (86-21) 61402666 f (86-21) 64958763

www.sgs.com
e sgs.china@sgs.com



Ding	134	150	110	52
Liu	120	135	117	50
Ye	126	137	105	52

Clause 7.9.2 Penetration of Filter Material

(EN 149:2001+A1:2009, Clause 8.11 & EN 13274-7:2019)

Test Requirement			Results	Comment
The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.				
Classification	Maximum penetration of test aerosol			
	Sodium chloride test 95 l/min	Paraffin oil test 95 l/min		
	% max.	% max.		
FFP1	20	20		
FFP2	6	6		
FFP3	1	1		

Appendix 2: Summarization of Test Data

Penetration of filter material

Aerosol	Condition	Sample No.	Penetration (%)
Sodium chloride test	As received	1	0.526
		2	0.434
		3	0.472
	Simulated wearing treatment	4	0.503
		5	0.468
		6	0.452
	Mechanical strength +Temperature conditioned	7	1.234
		8	1.346
		9	1.174
Paraffin oil test	As received	10	0.512
		11	0.557
		12	0.607
	Simulated wearing treatment	13	0.532
		14	0.587
		15	0.519
	Mechanical strength +Temperature conditioned	16	2.374
		17	2.264
		18	2.472
Flow conditioning: Single filter: 95.0 L/min			



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
 3rd Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgs.com.cn
 中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Clause 7.10 Compatibility with Skin

(EN 149:2001+A1:2009, Clause 8.4 & 8.5)

Test Requirement	Results	Comment
Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.	No irritation or any other adverse effect to health	Pass

Clause 7.11 Flammability

(EN 149:2001+A1:2009, Clause 8.6)

Test Requirement	Results	Comment
The material used shall not present a danger for the wearer and shall not be of highly flammable nature When tested, the particle filtering half mask shall not burn or not to continue to burn for more than 5 s after removal from the flame.	Detail refer to Appendix 3	Pass

Appendix 3: Summarization of Test Data

Flammability

Condition	Sample No.	Result
As received	1	NIL
	2	NIL
Temperature conditioned	3	NIL
	4	NIL

Clause 7.12 Carbon Dioxide Content of The Inhalation Air

(EN 149:2001+A1:2009, Clause 8.7)

Test Requirement	Results	Comment
The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1,0 % (by volume)	Detail refer to Appendix 4	Pass

Appendix 4: Summarization of Test Data

Carbon Dioxide Content of The Inhalation Air

Condition	Sample No.	Result(%)
As received	1	0.4640
	2	0.4637
	3	0.4625
		Mean value: 0.46



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
 3rd Building, No. 889, Yishan Road, Xuhui District Shanghai, China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgs.com.cn
 中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Clause 7.13 Head Harness

(EN 149:2001+A1:2009, Clause 8.4 & 8.5)

Test Requirement	Results	Comment
The head harness shall be designed so that the particle filtering half mask can be donned and removed easily.	Comply	Pass
The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and be capable of maintaining total inward leakage requirements for the device.	Comply	

Clause 7.14 Field of Vision

(EN 149:2001+A1:2009, Clause 8.4)

Test Requirement	Results	Comment
The field of vision is acceptable if determined so in practical performance tests.	Comply	Pass

Clause 7.15 Exhalation Valve(s)

(EN 149:2001+A1:2009, Clause 8.2 & 8.9.1 & 8.3.4 & 8.8)

Test Requirement	Results	Comment
(a) A particle filtering half mask may have one or more exhalation valve(s), which shall function correctly in all orientations.	Not applicable due to No exhalation valve	N.A.
(b) If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9.	Not applicable due to No exhalation valve	
(c) Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30 s.	Not applicable due to No exhalation valve	
(d) When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 10N applied for 10 s.	Not applicable due to No exhalation valve	



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

3rd Building, No. 889, Yishan Road, Xuhui District Shanghai, China 200233
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233

t (86-21) 61402666 f (86-21) 64958763
t (86-21) 61402666 f (86-21) 64958763

www.sgs.com.cn
e sgs.china@sgs.com

Clause 7.16 Breathing Resistance

(EN 149:2001+A1:2009, Clause 8.9)

Test Requirement				Results	Comment
The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.				Detail refer to Appendix 5	Meet FFP1, Meet FFP2, Meet FFP3
Classification	Maximum permitted resistance (mbar)				
	Inhalation		Exhalation		
	30 l/min	95 l/min	160 l/min		
FFP1	0.6	2.1	3.0		
FFP2	0.7	2.4	3.0		
FFP3	1.0	3.0	3.0		

Appendix 5: Summarization of Test Data

Breathing resistance (mbar)

As received	Flow rate(l/min)		1					2					3				
			A	B	C	D	E	A	B	C	D	E	A	B	C	D	E
	Inhalation	30	0.4	0.5	0.5	0.4	0.5	0.4	0.4	0.5	0.4	0.5	0.5	0.4	0.4	0.5	0.5
Simulated wearing treatment	Inhalation	95	1.5	1.6	1.6	1.5	1.5	1.6	1.6	1.5	1.5	1.6	1.6	1.5	1.6	1.6	1.5
		160	2.7	2.8	2.7	2.7	2.8	2.7	2.7	2.8	2.7	2.8	2.8	2.7	2.7	2.8	2.7
	Exhalation	160	2.7	2.8	2.7	2.7	2.8	2.7	2.7	2.8	2.7	2.8	2.7	2.8	2.7	2.8	2.7
Temperature conditioned	Flow rate(l/min)		4					5					6				
			A	B	C	D	E	A	B	C	D	E	A	B	C	D	E
	Inhalation	30	0.5	0.5	0.4	0.4	0.3	0.4	0.3	0.4	0.5	0.5	0.4	0.5	0.5	0.4	0.5
Temperature conditioned	Inhalation	95	1.6	1.5	1.6	1.6	1.6	1.5	1.6	1.5	1.6	1.6	1.5	1.6	1.5	1.6	1.5
		160	2.7	2.7	2.8	2.8	2.7	2.7	2.8	2.7	2.7	2.8	2.7	2.8	2.8	2.7	2.8
	Exhalation	160	2.8	2.7	2.7	2.8	2.7	2.7	2.8	2.7	2.7	2.8	2.7	2.7	2.8	2.8	2.7

A: facing directly ahead; B: facing vertically upwards; C: facing vertically downwards; D: lying on the left side; E: lying on the right side



Clause 7.17 Clogging

(EN 149:2001+A1:2009, Clause 8.9 & 8.10)

Test Requirement	Results	Comment																			
<p><u>Clause 7.17.2 Breathing resistance</u> <u>Valved particle filtering half masks:</u> After clogging the inhalation resistances shall not exceed: FFP1: 4 mbar, FFP2: 5 mbar, FFP3: 7 mbar at 95L/min continuous flow The exhalation resistance shall not exceed 3 mbar at 160 L/min continuous flow.</p> <p><u>Valveless particle filtering half masks:</u> After clogging the inhalation and exhalation resistances shall not exceed: FFP1: 3 mbar, FFP2: 4 mbar, FFP3: 5 mbar at 95L/min continuous flow</p>	Optional for single shift device only	N.A.																			
<p><u>Clause 7.17.3 Penetration of filter material</u> All types (valved and valveless) of particle filtering half masks claimed to meet the clogging requirement shall also meet the requirements.</p> <table border="1"> <thead> <tr> <th rowspan="3">Classification n</th><th colspan="2">Maximum penetration of test aerosol</th></tr> <tr> <th>Sodium chloride test 95 l/min</th><th>Paraffin oil test 95 l/min</th></tr> <tr> <th>%</th><th>%</th></tr> </thead> <tbody> <tr> <td></td><td>max.</td><td>max.</td></tr> <tr> <td>FFP1</td><td>20</td><td>20</td></tr> <tr> <td>FFP2</td><td>6</td><td>6</td></tr> <tr> <td>FFP3</td><td>1</td><td>1</td></tr> </tbody> </table>	Classification n	Maximum penetration of test aerosol		Sodium chloride test 95 l/min	Paraffin oil test 95 l/min	%	%		max.	max.	FFP1	20	20	FFP2	6	6	FFP3	1	1	Optional for single shift device only	N.A.
Classification n		Maximum penetration of test aerosol																			
		Sodium chloride test 95 l/min	Paraffin oil test 95 l/min																		
	%	%																			
	max.	max.																			
FFP1	20	20																			
FFP2	6	6																			
FFP3	1	1																			

Clause 7.18 Demountable Parts

(EN 149:2001+A1:2009, Clause 8.2)

Test Requirement	Results	Comment
All demountable parts (if fitted) shall be readily connected and secured, where possible by hand	No demountable parts	N/A


Test	Uncertainty
Total inward leakage	3.4%
Penetration of filter material	4.8%
Carbon dioxide content of the inhalation air	3.9%
Breathing resistance (30L/min)	5.9%
Breathing resistance (95L/min)	4.9%
Breathing resistance (160L/min)	4.3%




Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
 3rd Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgs.com.cn
 中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Sample Photo





End of Report



Atenschutzmaske

Benutzeranleitung:

Die Nichtbeachtung der Anweisungen und Warnungen zur Verwendung dieser Maske kann die Wirksamkeit der Maske beeinträchtigen.

Vor dem Gebrauch sollte stets überprüft werden, ob sich die Maske in einem einwandfreien Zustand befindet und diese keine Verschmutzungen oder Beschädigungen aufweist.

Einschränkungen:

Verwenden Sie unter folgenden Umständen die Atemschutzmaske nicht bzw.

halten Sie sich von kontaminierten Bereichen fern:

A: die Raumluft enthält weniger als 19.5% Sauerstoff

B: Sie riechen oder schmecken Verunreinigungen

C: zum Schutz vor Gasen oder Dämpfen

D: Verschmutzungen oder deren Konzentrationen sind unbekannt oder unmittelbar lebens- und gesundheitsgefährdend

E: zum Sandstrahlen, Sprühen und zur Asbestbehandlung

F: in explosionsgefährdeten Bereichen

Warnungen:

1. Die mit „NR“ gekennzeichnete Maske darf nicht länger als eine Schicht verwendet werden.

2. Ersetzen oder ändern Sie niemals Teile in der vom Hersteller produzierten Maske. Auch vom Hinzufügen sämtlicher Teile ist abzusehen.

3. Diese Maske schützt vor der Übertragung von bestimmten Partikeln, schließt jedoch das Risiko einer Krankheit oder Infektion nicht vollständig aus.

4. Wenn das Gesichtshaar unter der Gesichtversiegelung verläuft, kann die Maske nicht den gewünschten Schutz bieten.

5. Wechseln Sie die Maske sofort, wenn Ihnen das Atmen schwer fällt, die Maske beschädigt oder verrutscht ist.

6. Wechseln Sie die Maske, wenn keine ordnungsgemäße Abdichtung erreicht werden kann.

Lagerung:

1. Bewahren Sie die Maske in einem verschlossenen Behälter auf, wenn Sie diese nicht verwenden.

2. Bewahren Sie die Maske während des Transports in der Originalverpackung auf.

Adresse: No.39-40, Xiangdong Village, Qianku Town, Cangnan County, Wenzhou City, Zhejiang Province CHINA


Hersteller: Cangnan County Jiawei Bag Making Factory
Tel: 0577-64486858

Europäischer Importeur / European Importer:

Paul Schinke - mobile Doc.
Dufourstrasse 25
04107 Leipzig
Germany



4 260717 162001 4



4
Falls beschädigt, austauschen, bitte mit neuer Maske ersetzen




3
Die Nasenklammer anpassen, möglichst nah ans Gesicht bringen



2
Nah ans Gesicht, Mund & Kinn vollständig bedeckt



1
Die Vorderseite nach oben, Riemen über Ohren ziehen



宽4.5 长12 高12.5 cm



Partikel-filtrierende Atemschutzmaske

FFP2 NR

Verordnung(EU)2016/425
Nicht-medizinisch



Einstellbarer Nasenclip

☒ einstellbarer Nasenclip

☒ bessere Dichtheit

☒ geringer Atemwiderstand

☒ umfassender Schutz

EN 149:2001+A1:2009 FFP2 NR

10
pcs

CE 0598




2021.01.15




2023.01.14

LOT

20210115



Verordnung (EU) 2016/425
Nicht-medizinisch



C € 0598



Partikel-filtrierende Atemschutzmaske

FFP2 NR

Verordnung(EU)2016/425

Nicht-medizinisch



Einstellbarer Nasenclip

☒ einstellbarer Nasenclip

☒ bessere Dichtheit

☒ geringer Atemwiderstand

☒ umfassender Schutz


EN 149:2001+A1:2009 FFP2 NR







10
pcs

CE 0598

● **Gebrauchsanweisung**

- 1 Halten Sie die Maske über Nase und Mund.
- 2 Legen Sie die Ohrschlaufen hinter die Ohren.
- 3 Drücken Sie den Nasenclip an der Oberseite der Maske an die Wangen.
- 4 Prüfen Sie den korrekten Sitz, indem Sie beide Hände über die Maske halten und atmen Sie kräftig. Falls Luft an den Seiten oder der Oberseite ausstritt, passen Sie Ohrschlaufen oder Nasenclip an, bis die Abdichtung ordnungsgemäß ist.
- 5 Nur eine ordnungsgemäße Abdichtung kann die vollständige Schutzwirkung der Maske gewährleisten.



	Calendar (optional): Date expired
	Herstellungsjahr/ Date of manufacture
	Chargennummer/ Batch code
	Nicht wiederverwenden! Do not reuse
	Siehe die Angaben des Herstellers/Siehe die Information gegeben by the manufacturer
	Lagerungsmasse Luftfeuchtigkeit Maximum Relative Humidity
	Temperaturbereich/Temperature range
	Hersteller/Manufacturer

Certification of Approval

Product Name: Particle Filtering Half Mask (Non-Medical Face Mask)

Model & Specification: CNJN-2020 FFP2 NR

Material Composition: Double S25g non-woven fabric, 25g melt-blown fabric.

400g hot air cotton

product Quantity: 1 Piece Pack:

Executive Standard EN 149:2001+A1:2009

Batch Code: 20200725

Date of Manufacture 2020 12 30

Usage by Date: 2022-12-29

Valid for 24 Months

Introduction 01

*For more information please refer to the instruction on the package

Adresse: no 38-40 Jiangdong Village Quhai Town, Cangnan County, Wenzhou City,

Zhejiang Province CHINA

Hersteller: Cangshan County Jiansi Bag Making Factory

78015577-6444862-58

Made in China



C E 0598

